




Date: September 27, 2018

CERTIFICATE OF COMPLIANCE

This certificate of compliance validates the following			
TEST REPORT NUMBER	1. 3487/BA/07 2. 3822/BA/07 3. 138/BA/13 4. 319/BA/17	CERTIFICATE NUMBER	DC - UAE - 0105
DATE OF ISSUE	1. May 29, 2007 2. January 23, 2008 3. April 26, 2013 4. October 6, 2017	DATE OF ISSUE	September 27, 2018
DATE OF EXPIRY	Not applicable	DATE OF EXPIRY	December 11, 2027
Manufacturer details			
NAME OF FACTORY / MANUFACTURER	POLON-ALFA S.A.	NAME OF THE BRAND	POLON-ALFA
FACTORY ADDRESS / REGION	ul. Glinki 155 85-861 Bydgoszcz Republic of Poland	MODEL / NO	POLON 4200
WEBSITE	www.polon-alfa.pl	LOGO ON THE PRODUCT	
TELEPHONE	+48 52 36 39 269	EMAIL	export@polon-alfa.pl tomasz.piaskowski@polon-alfa.pl





Product Details From Test Report		Reference Test Report Page No.
DESCRIPTION OF THE PRODUCT	Control and indicating equipment type POLON 4200 (Detailed specification below)	3
TESTS STANDARD	EN 54-2:1997 + AC:1999 + A1:2006 Fire detection and fire alarm systems - Part 2: Control and indicating equipment EN 54-4:1997 + AC:1999 + A1:2002 + A2:2006 Fire detection and fire alarm systems - Part 4: Power supply equipment	6
TESTS DESCRIPTION	Requirements, test methods and performance criteria for control and indicating equipment intended to broadcast a warning of fire between a fire detection and fire alarm system and the occupants of a building.	6
SPECIFICATION OF TEST SPECIMEN	Parameters of CIE type POLON 4200	
	Type:	POLON 4200
	Version of CIE:	addressable
	IP protection:	IP30
	Operating temperature:	-5 °C ÷ +40 °C
	Dimensions (Length x Width x Height):	190 x 393 x 483 mm
	Software version:	V2.74
	Main supply - supply voltage:	230 V AC
	Maximum current consumption:	0,8 A
	Internal working voltage:	24 V DC
	Power supply; battery type:	lead-acid (sealed) 2 x 12 V DC
	Maximum battery capacity:	38 Ah
	Detector lines: type of detector lines:	loop, open
	Number of detector lines:	4 pieces
	Maximum number of elements in the detector line:	64 pieces
	Voltage of the detector line:	23,4 V DC ÷ 24,6 V DC
	Maximum current in stand-by mode:	50 mA
	Monitored signal lines:	2 pieces
	Inputs:	2 pieces (supervised)
	Outputs:	8 pieces
	Parameters of integral power supply	
	Basic data	
	Type of power supply:	electric
	Output operating current I _{max.a} :	0,6 A
	Output operating current I _{max.b} :	0,6 A
	Output circuits: range of output voltage:	24 V DC
	Main supply	
Main supply: supply voltage:	230 V AC -15% +10%	
Input circuits: number of inputs:	2	
Reserve supply		
Maximum voltage of battery charging:	26,7 ÷ 27,3 V DC	
Maximal internal resistance of the battery and elements connected to the battery circuit:	1 Ω	
Temperature compensation in floating mode:	yes	
Product components (basic and optional): MZ-4212; PSC-43; DR-48; MSL-1M-42; PS-49; PAR-4800; TSO-4200; PPW-42; PK; LS; LK; PORT 1, PORT 2; TSR-4000.		



TESTS RESULTS	EN 54-2	General requirements	PASS	
	EN 54-2	General requirements for indications	PASS	
	EN 54-2	The fire alarm condition	PASS	
	EN 54-2	Reception and processing of fire signals	PASS	
	EN 54-2	Output of the fire alarm condition	PASS	
	EN 54-2	Delay to outputs	PASS	
	EN 54-2	Dependencies on more than one alarm signal	PASS	
	EN 54-2	General requirements	PASS	
	EN 54-2	General requirements for indications	PASS	
	EN 54-2	The quiescent condition	PASS	
	EN 54-2	The fire alarm condition	PASS	
	EN 54-2	Fault warning condition	PASS	
	EN 54-2	Disabled condition	PASS	
	EN 54-2	Test condition	PASS	
	EN 54-2	Standardized input/output interface	PASS	
	EN 54-2	Design requirements	PASS	
	EN 54-2	Additional design requirements for software controlled control and indicating equipments	PASS	
	EN 54-2	Marking	PASS	
	EN 54-2 - EN 60068-2-1	Cold (operational)	PASS	
	EN 54-2 - EN 60068-2-75	Impact (operational)	PASS	
	EN 54-2 - EN 60068-2-6	Vibration, sinusoidal (operational)	PASS	
	EN 54-2 - EN 60068-2-6	Vibration, sinusoidal (endurance)	PASS	
	EN 54-2 - EN 50130-4	Electromagnetic compatibility (EMC), immunity tests (operational)	PASS	9-33 (3487/BA/07)
	EN 54-2	Supply voltage variations	PASS	8-24 (3822/BA/07)
	EN 54-2 - EN 60068-2-78	Damp heat, steady state (operational)	PASS	7 (138/BA/13)
	EN 54-2 - EN 60068-2-78	Damp heat, steady state (endurance)	PASS	7-9 (319/BA/17)
	EN 54-2	Fault signals from points	PASS	
	EN 54-2	Total loss of the power supply	PASS	
	EN 54-2	Alarm counter	PASS	
	EN 54-2	Dependencies on more than one alarm signal	PASS	
	EN 54-2	Delay to outputs	PASS	
	EN 54-2	Disablement of addressable points	PASS	
	EN 54-2	Test condition	PASS	
	EN 54-2	Output to fire alarm devices	PASS	
EN 54-2	Alarm transmission routing equipment	PASS		
EN 54-2	Output for fire protection equipment	PASS		
EN 54-2	Fault warning routing equipment	PASS		
EN 54-2	Standardized input / output interface	PASS		
EN 54-4	General requirements	PASS		
EN 54-4	Functions	PASS		
EN 54-4	Materials, design and manufacture	PASS		
EN 54-4	General requirements	PASS		
EN 54-4	Functions	PASS		
EN 54-4	Materials, design and manufacture	PASS		
EN 54-4	Documentation	PASS		
EN 54-4	Marking	PASS		
EN 54-4 - EN 60068-2-1	Cold (operational)	PASS		
EN 54-4 - EN 60068-2-75	Impact (operational)	PASS		
EN 54-4 - EN 60068-2-6	Vibration, sinusoidal (operational)	PASS		
EN 54-4 - EN 60068-2-6	Vibration, sinusoidal (endurance)	PASS		
EN 54-4 - EN 50130-4	Electromagnetic compatibility (EMC), immunity tests (operational)	PASS		
EN 54-4 - EN 60068-2-78	Damp heat, steady state (operational)	PASS		
EN 54-4 - EN 60068-2-78	Damp heat, steady state (endurance)	PASS		
PRODUCT APPLICATION GUIDELINE	KK-E300/05.2015	Control and indicating equipment with power supply equipment type POLON 4200 is used in fire detection and fire alarm systems. It is equipped with an integrated power supply. Control and indicating equipment has two 2 power sources: main supply and reserve supply.		Not applicable



Laboratory and Certification Body Details

NAME OF CERTIFICATION BODY	CNBOP-PIB Centrum Naukowo-Badawcze Ochrony Przeciwpożarowej Państwowy Instytut Badawczy	NAME OF TEST FACILITY	CNBOP-PIB Zespół Laboratoriów Sygnalizacji Alarmu Pożaru i Automatyki Pożarniczej
CERTIFICATION BODY ADDRESS / REGION	ul. Nadwiślańska 213 05-420 Józefów REPUBLIC OF POLAND	TEST FACILITY ADDRESS / REGION	ul. Nadwiślańska 213 05-420 Józefów REPUBLIC OF POLAND
WEBSITE	www.cnbop.pl	WEBSITE	www.cnbop.pl
TELEPHONE	+48 22 769 33 47	TELEPHONE	+48 22 769 32 26
EMAIL	jcw@cnbop.pl	EMAIL	ba@cnbop.pl
ACCREDITED BY	Polish Centre for Accreditation http://www.pca.gov.pl	ACCREDITED BY	Polish Centre for Accreditation http://www.pca.gov.pl
AS PER	EN ISO/IEC 17065 Requirements for bodies certifying products, processes and services	AS PER	EN ISO/IEC 17025 General requirements for the competence of testing and calibration laboratories
VALIDITY	October 3, 2022	VALIDITY	October 11, 2021
REFERENCE NUMBER	AC 063	REFERENCE NUMBER	AB 207
CERTIFICATION MARK			
(ENDORSEMENT) TO BE SIGNED BY MANUFACTURER			
NAME AND SURNAME OF MANUFACTURERS SIGNATORY	DARIUSZ NAGANISKI	SIGNATURE	
EMAIL / TELEPHONE	+48 523639261 export@polar-alfa.pl	FACTORY OFFICIAL SEAL	POLON-ALFA S.A. ul. Glinki 155 85-861 BYDGOSZCZ
NOTES	I UNDERTAKE THAT ALL DATA AND INFORMATION PROVIDED ARE GENUINE AND ACCURATE.		
(ENDORSEMENT) TO BE CERTIFICATION BODY			
NAME AND SURNAME OF CERTIFICATION BODY SIGNATORY	bryg. dr inż Jacek Zboina	SIGNATURE	
EMAIL / TELEPHONE	cnbop@cnbop.pl +48 22 769 33 00	CERTIFICATION BODY OFFICIAL SEAL	
NOTES	I UNDERTAKE THAT ALL DATA AND INFORMATION PROVIDED ARE GENUINE AND ACCURATE.		

ATTACHMENT:

COPY OF "CERTIFICATE OF CONSTANCY OF PERFORMANCE" NO. 1438-CPR-0128 ISSUED BY CERTIFICATION BODY